

**Removal Of Asbestos Pipe | SAFE WORK METHOD STATEMENT (SWMS)**

**TASK OR ACTIVITY: Removal Of Asbestos Pipe**

Business Name: [Company Name]		ABN: [ABN]	SWMS#
Business Address: [Company Address]			
Contact Person:	Phone: [Phone]	Email:	

**THIS SAFE WORK METHOD STATEMENT IS APPROVED BY THE PCBU OF THE PROJECT**

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a safe work method statement (SWMS) is prepared before the proposed work starts.

Full Name:

Signature: \_\_\_\_\_ Title: \_\_\_\_\_ Date: \_\_\_\_\_

Details of the person(s) responsible for ensuring implementation, monitoring and compliance of the SWMS, as well as reviews and modifications of the SWMS.

Full Name: \_\_\_\_\_ Title: \_\_\_\_\_ Phone: \_\_\_\_\_

**ALL PERSONNEL PARTICIPATING IN ANY ACTIVITY ON THIS SWMS MUST HAVE THE FOLLOWING COMMUNICATED** | **NAME AND DATED SIGNATURE OF ALL RELEVANT PERSONNEL WHO HAVE BEEN CONSULTED AND COMMUNICATED TO IN THE DEVELOPMENT AND APPROVAL OF THIS SWMS**

	NAME	SIGNATURE	DATE
Safety meetings or toolbox talks will be scheduled in accordance with legislative requirements to first identify any site hazards, to conduct and communicate those hazards and then to further take steps to either eliminate or control each hazard.			
If an incident or a near miss occurs, all work must stop immediately. Depending on the severity of the incident, a meeting will be called with all workers to amend the SWMS if required. The meeting may also be an educational opportunity.			
Any changes made to the SWMS after an incident or a near miss must be approved by the Person Conducting Business or Undertaking and communicated to all relevant personnel.			
The SWMS must be kept and be available for inspection at least until the work is completed. Where a SWMS is revised, all versions should be kept. If a notifiable incident occurs in relation to which the SWMS relates, then the SWMS must be kept for at least two years from the occurrence of the notifiable incident.			

**CLIENT OR PRINCIPAL CONTRACTOR DETAILS**

Client:	SCOPE OF WORKS Provide a detailed description of the specific work being carried out (otherwise known as scope of works).
Project Name:	
Project Address:	
Project Manager:	
Contact Phone:	
Project Manager Signature:	
Date SWMS supplied to Project Manager:	

**ANY HIGH-RISK CONSTRUCTION WORK BEING CARRIED OUT**

<input type="checkbox"/> involves a risk of a person falling more than 2 meters.	<input type="checkbox"/> is carried out on or near pressurised gas mains or piping.
<input type="checkbox"/> is carried out on a telecommunication tower.	<input type="checkbox"/> is carried out on or near chemical, fuel or refrigerant lines.
<input type="checkbox"/> involves demolition of an element of a structure that is load-bearing.	<input type="checkbox"/> is carried out on or near energised electrical installations or services.
<input type="checkbox"/> involves demolition of an element related to the physical integrity of a structure.	<input type="checkbox"/> is carried out in an area that may have a contaminated or flammable atmosphere.
<input type="checkbox"/> involves, or is likely to involve, disturbing asbestos.	<input type="checkbox"/> involves tilt-up or precast concrete.
<input type="checkbox"/> involves structural alteration or repair that requires temporary support to prevent collapse.	<input type="checkbox"/> is carried out on, in or adjacent to a road, railway, shipping lane or other traffic corridor.
<input type="checkbox"/> is carried out in or near a confined space.	<input type="checkbox"/> is carried out in an area of a workplace where there is any movement of powered mobile plant.
<input type="checkbox"/> is carried out in/near a shaft or trench deeper than 1.5m or tunnel involving use of explosives.	<input type="checkbox"/> is carried out in areas with artificial extremes of temperature.
<input type="checkbox"/> is carried out in or near water or other liquid that involves a risk of drowning.	<input type="checkbox"/> involves diving work.

**ANY HIGH-RISK MACHINERY OR EQUIPMENT NEARBY**

<input type="checkbox"/> Forklift	<input type="checkbox"/> Crane/s	<input type="checkbox"/> Hoist/s	<input type="checkbox"/> Excavator	<input type="checkbox"/> Backhoe/Loader	<input type="checkbox"/> Boom Lift	<input type="checkbox"/> EWP	<input type="checkbox"/> Genie Lift
<input type="checkbox"/> Trencher	<input type="checkbox"/> Drilling Rig	<input type="checkbox"/> Trucks	<input type="checkbox"/> Formwork	<input type="checkbox"/> Bobcat	<input type="checkbox"/> Flammable Gas	<input type="checkbox"/> Fuel	<input type="checkbox"/> Dozer
<input type="checkbox"/> High Voltage	<input type="checkbox"/> Mulcher	<input type="checkbox"/> Tilt-up Panels	<input type="checkbox"/> Roller	<input type="checkbox"/> Scissor Lift	<input type="checkbox"/> Tractor	<input type="checkbox"/> Other -	

**RISK MATRIX**

LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION	HEIRARCHY OF CONTROLS
ALMOST CERTAIN	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4 ACUTE			<b>Elimination</b> Remove the hazard.
LIKELY	2 MODERATE	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4A ACUTE	DO NOT PROCEED	<b>Substitution</b> Replace the hazard.
POSSIBLE	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	4 ACUTE	3H HIGH	Review before work starts.	<b>Isolation</b> Isolate People from the hazard
UNLIKELY	1 LOW	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	2M MODERATE	Ensure control measures in place.	<b>Engineering</b> Isolate the hazard.
RARE	1 LOW	1 LOW	2 MODERATE	3 HIGH	3 HIGH	1L LOW	Monitor and keep records	<b>Administrative</b> Change the work. <b>PPE</b>

**Notes on Hierarchy of Controls:** Elimination methods are the most effective and preferred when controlling a hazard. Substitution is the second most effective method of controlling a hazard. Engineering by isolation is the third most effective, while Administrative Controls by changing the work is the fourth most effective method. PPE (Personal Protective Equipment) is the least effective method.

**PERSONAL PROTECTIVE EQUIPMENT (PPE)**

FOOT PROTECTION	HAND PROTECTION	HEAD PROTECTION	HEARING PROTECTION	EYE PROTECTION	RESPIRATORY PROTECTION	FACE PROTECTION	HIGH-VIS CLOTHING	PROTECTIVE CLOTHING	FALL PROTECTION	SUN PROTECTION	HAIR/JEWELLERY SECURED
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>


Select the appropriate PPE above suitable for the equipment used or the job task being performed (if applicable).

**Note:** A SWMS must be reviewed regularly to make sure it remains effective. A SWMS must be reviewed (and revised if necessary) if relevant control measures are revised. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When a SWMS has been revised, the person conducting a business or undertaking must ensure all:

1. persons involved in the work are advised that a revision has been made and how they can access the revised SWMS;
2. persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS; and,
3. workers that will be involved in the work are provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
1. Preparation	Incorrect identification of asbestos. Lack of proper tools and equipment	2M	<ul style="list-style-type: none"> <li>- Proper identification: Ensure correct identification of asbestos material by engaging a qualified asbestos assessor with the required licenses and certification to perform surveys and tests.</li> <li>- Update asbestos register: Keep an updated asbestos register in the workplace, clearly indicating the location of asbestos-containing materials (ACMs) to avoid accidental exposure or disturbance.</li> <li>- Develop an Asbestos Management Plan: Establish a clear plan outlining procedures for removal, transportation, and disposal of ACMs including roles and responsibilities of all parties involved.</li> <li>- Obtain necessary permits/licenses: Ensure that all necessary permits and licenses are obtained from relevant authorities before commencing the removal of asbestos pipe.</li> <li>- Appropriate training of workers: Conduct regular training sessions for employees to ensure they understand the hazards associated with asbestos and how to safely handle it.</li> <li>- Personal Protective Equipment (PPE): Provide appropriate PPE, such as respirators, protective coveralls, gloves, and safety goggles, to every worker involved in asbestos removal tasks.</li> <li>- Select proper tools and equipment: Use specialised tools and equipment designed specifically for asbestos removal, minimising the risk of airborne fiber release.</li> <li>- Restrict access to work area: Only allow authorised personnel to enter the asbestos removal site, ensuring warning signs are placed around the perimeter of the work area.</li> <li>- Implement control measures: Apply suitable control measures, including wet methods or dust suppression technology to minimise the release of asbestos fibers during removal.</li> <li>- Secure waste containers: Use leak-tight containers or heavy-duty double-bagged bags to securely transport and store removed asbestos waste until proper disposal.</li> <li>- Inspection and maintenance of equipment: Regularly inspect and maintain tools and equipment used in the removal process, replacing any damaged or inefficient items.</li> <li>- Adequate communication and supervision: Ensure clear communication between workers and supervisors throughout the entire process, with regular briefings and consultation periods.</li> <li>- Post-removal cleaning: Thoroughly clean the work area after removal using wet wiping and HEPA-filtered vacuuming methods, ensuring complete decontamination of any remaining ACM debris or dust.</li> </ul>	1L	
2. Isolation	Airborne asbestos exposure, Uncontrolled access to the work area	3H	<ul style="list-style-type: none"> <li>- Implement exclusion zones: Set up clearly marked exclusion zones around the work area to ensure only authorised personnel can access the site. Use physical</li> </ul>	2M	



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<p>barriers, such as fencing or barricades, and warning signs to indicate the presence of asbestos.</p> <ul style="list-style-type: none"> <li>- Establish personal protective equipment (PPE) requirements: Ensure all workers involved in the removal of asbestos pipe are wearing appropriate PPE, such as disposable coveralls, gloves, boot covers, and respiratory protection, to minimise exposure to airborne asbestos fibers.</li> <li>- Air monitoring: Conduct regular air monitoring during the asbestos pipe removal process to measure the concentration of airborne asbestos fibers and ensure that levels remain within safe limits.</li> <li>- Dust suppression: Implement methods, such as dampening surfaces or utilising HEPA-filtered vacuum systems, to suppress any dust generated during the removal process, thereby minimising the release of airborne asbestos fibers.</li> <li>- Encapsulation: Apply encapsulants (specifically designed for asbestos containment) to seal the surface of the asbestos pipe before removing it, which could prevent the release of asbestos fibers into the air.</li> <li>- Implement clearance procedures: Develop and follow clearance procedures, including visual inspections and air monitoring, to ensure the work area is free from asbestos contamination after the removal has been completed.</li> <li>- Proper waste disposal: Dispose of asbestos-containing materials (ACM) in accordance with local regulations in waste containers that are properly labelled and sealed. Ensure that waste transport and disposal are carried out by licensed operators.</li> <li>- Training and competency: Ensure all workers involved in the asbestos removal process have received appropriate training on the hazards, safe work practices, and regulatory requirements associated with asbestos.</li> <li>- Communication and coordination: Coordinate with other trades, supervisors, and workers to ensure they understand the hazards and specific requirements for the isolation and removal of asbestos pipes. Hold regular toolbox talks to reinforce this information and maintain open communication on-site.</li> <li>- Periodic review and update of SWMS: Regularly review and update the Safe Work Method Statement (SWMS) for asbestos pipe removal to ensure its continued effectiveness in addressing hazards and implementing appropriate control measures. Consider changes to work processes, technologies, or legislative requirements when updating the SWMS.</li> </ul>		
3. Decontamination set up	Poor decontamination facilities, Insufficient PPE usage	2M	<ul style="list-style-type: none"> <li>- Establish a designated decontamination area adjacent to the work site, ensuring it is well-ventilated and free from obstructions.</li> <li>- Set up a three-stage decontamination process that includes a dirty area, a shower area, and a clean area for workers to transition through after handling asbestos.</li> <li>- Provide clear signage indicating the boundaries of each decontamination area and emphasise the importance of following the proper sequence when entering and exiting the zones.</li> </ul>	1L	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> <li>- Equip the decontamination area with appropriate cleaning supplies, such as HEPA-filtered vacuum cleaners, disposable wipes, and waste receptacles lined with asbestos-proof bags.</li> <li>- Ensure workers are adequately trained on decontamination procedures, including the proper removal, cleaning, and disposal of personal protective equipment (PPE) and clothing.</li> <li>- Supply workers with sufficient quantities and proper sizes of PPE, including coveralls, gloves, footwear, and respiratory masks meeting Australian regulatory standards.</li> <li>- Instruct workers to change into clean clothing after completing decontamination processes and before leaving the work site to minimise potential cross-contamination.</li> <li>- Conduct regular inspections of the decontamination area to ensure all supplies and equipment are functioning correctly and promptly address any deficiencies or malfunctions.</li> <li>- Implement a strict buddy system during decontamination procedures to ensure that workers are correctly following guidelines and assisting one another in the safe removal and disposal of contaminated PPE.</li> <li>- Develop a protocol for handling emergency situations within the decontamination area, ensuring that workers know how to respond swiftly and efficiently in case of exposure or injury.</li> <li>- Keep records of all workers who have entered and exited the decontamination area, including details about the nature of their work, the duration of their exposure, and associated PPE usage.</li> <li>- Store all removed asbestos materials securely, sealing them in properly labelled double-layered plastic bags, away from general work areas until they can be disposed of according to local regulations.</li> <li>- Coordinate with certified asbestos disposal services for the prompt and compliant removal, transportation, and disposal of contaminated materials generated during decontamination processes.</li> <li>- Regularly update and review the Safe Work Method Statement (SWMS) for asbestos pipe removal to ensure compliance with Australian Workplace Health and Safety regulations and reflect any new findings or modifications in industry practices regarding decontamination procedures.</li> </ul>		
4. Encapsulation	Ineffective enclosure, Premature damage to encapsulated materials	3H	<div style="background-color: black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="background-color: black; width: 100%; height: 20px; margin-bottom: 5px;"></div>	2M	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
5. Removal of asbestos pipe	Asbestos fibers dispersion, Cuts or abrasions from sharp edges	3H	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
6. Waste Disposal	Improper waste disposal, Contamination of the environment	4A	[REDACTED]	2M	
			[REDACTED]		
			[REDACTED]		

SAMPLE





JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
8. Clean-up	Remaining asbestos debris, Improper cleaning methods	2M	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
9. Decontamination	Incomplete removal of contaminants from personnel and equipment Exposure to asbestos during decontamination process		[REDACTED]	2M	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
10. Clearance Inspection	Missed asbestos material failure to identify ongoing risks	3H	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
11. Site Restoration	Discarded PPE, Damaged property during removal process	2M	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
12. Documentation	Inaccurate or missing records, Miscommunication between stakeholders	3H	[REDACTED]	2M	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

**EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES**

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

**LEGISLATIVE REFERENCES**

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES FOR ANY STATE THAT ARE NOT APPLICABLE

<p><b>Queensland &amp; Australian Capital Territory</b>                  Work Health and Safety Act 2011                  Work Health and Safety Regulations 2011                  Legislation QLD: <a href="https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws">https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws</a>                  Codes of Practice QLD: <a href="https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice">https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice</a>                  Legislation ACT: <a href="https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations">https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations</a>                  Codes of Practice ACT: <a href="https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice">https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice</a></p>	<p><b>Victoria</b>                  Occupational Health and Safety Act 2004                  Occupational Health and Safety Regulations 2017                  Legislation VIC: <a href="https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations">https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations</a>                  Codes of Practice VIC: <a href="https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice">https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice</a></p>
<p><b>New South Wales</b>                  Work Health and Safety Act 2011                  Work Health and Safety Regulations 2017                  Legislation NSW: <a href="https://www.safework.nsw.gov.au/legal-obligations/legislation">https://www.safework.nsw.gov.au/legal-obligations/legislation</a>                  Codes of Practice NSW: <a href="https://www.safework.nsw.gov.au/resource-library/list-of-codes-of-practice">https://www.safework.nsw.gov.au/resource-library/list-of-codes-of-practice</a></p>	<p><b>Western Australia</b>                  Work Health and Safety Act 2020                  Work Health and Safety Regulations 2022                  Legislation Western Australia: <a href="https://www.commerce.wa.gov.au/worksafe/legislation">https://www.commerce.wa.gov.au/worksafe/legislation</a>                  Codes of Practice WA: <a href="https://www.commerce.wa.gov.au/worksafe/codes-practice">https://www.commerce.wa.gov.au/worksafe/codes-practice</a></p>
<p><b>Northern Territory</b>                  Work Health and Safety (National Uniform Legislation) Act 2011                  Work Health and Safety (National Uniform Legislation) Regulations 2011                  Legislation NT: <a href="https://worksafe.nt.gov.au/laws-and-compliance/workplaces-and-laws">https://worksafe.nt.gov.au/laws-and-compliance/workplaces-and-laws</a>                  Codes of Practice NT: <a href="https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice">https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice</a></p>	<p><b>Safe Work Australia Links</b>                  Law and Regulation (All States): <a href="https://www.safeworkaustralia.gov.au/law-and-regulation">https://www.safeworkaustralia.gov.au/law-and-regulation</a>                  Model Codes of Practice: <a href="https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice">https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice</a></p>
<p><b>South Australia</b>                  Work Health and Safety Act 2012 (SA)                  Work Health and Safety Regulations 2012 (SA)                  Legislation for SA: <a href="https://www.safework.sa.gov.au/resources/legislation">https://www.safework.sa.gov.au/resources/legislation</a>                  Codes of Practice for SA: <a href="https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs">https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs</a></p>	<p><b>Model Codes of Practice</b></p> <ul style="list-style-type: none"> <li>- Managing noise and preventing hearing loss at work</li> <li>- Confined spaces</li> <li>- Labelling of workplace hazardous chemicals</li> <li>- Managing risks of hazardous chemicals in the workplace</li> <li>- Welding processes</li> <li>- First aid in the workplace</li> <li>- Managing the risk of falls at workplaces</li> <li>- Hazardous manual tasks</li> <li>- Managing the risk of falls in housing construction</li> <li>- Managing electrical risks in the workplace</li> <li>- Demolition work</li> <li>- Excavation work</li> <li>- Work health and safety consultation, cooperation and coordination</li> <li>- Managing the work environment and facilities</li> <li>- How to manage work health and safety risks</li> <li>- Managing risks of plant in the workplace</li> <li>- Construction work</li> </ul>
<p>Details of permits, licenses or access required by regulatory bodies (add or delete as required):</p> <ul style="list-style-type: none"> <li>- Permits from local council</li> <li>- Authorisation to commence work</li> <li>- Any required documents.</li> </ul>	

**SIGNATORIES OF THE SAFE WORK METHOD STATEMENT**

The signed and dated personnel listed below have cooperated in the consultation and development of this Safe Work Method Statement which has been approved by the Person/s Conducting a Business or Undertaking (PCBU). In signing this Safe Work Method Statement each individual acknowledges and confirms that they have read this SWMS in full, having raised any questions for items on this Safe Work Method Statement that require clarification, and confirms that they are competent, skilled and knowledgeable for the task assigned to them. Every person acknowledges that they have received the relevant training and qualifications where required, before carrying out any work contained in this Safe Work Method Statement. By signing this Safe Work Method Statement each individual agrees to work safely, to follow any safe work instructions which are provided, and agrees to use all Personal Protective Equipment where appropriate.

Worker Name	Position	Signature	Date	Time	Supervisor
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		

**SAFE WORK METHOD STATEMENT MONITORING AND REVIEW**

**The SWMS must be reviewed regularly** to make sure it remains effective and must be reviewed (and revised if necessary) if relevant control measures are needed. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When the SWMS has been revised the PCBU must ensure that all persons involved with the work are advised that a revision has been made and how they can access the revised SWMS, including all persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS. All workers that will be involved in the work must be provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

**The SWMS must be monitored regularly** for the effectiveness of ensuring hazard controls are effective in reducing the risk of incidents, keeping the workplace safe for all personnel. The person responsible for monitoring the effectiveness of the Safe Work Method Statement should employ a multi-faceted approach which includes but is not limited to:

1. Spot Checks.
2. Consultation with workers, contractors and sub-contractors.
3. Internal audits on a continual basis.

An approach of continuous improvement, promptly recording inconsistencies or deficiencies, followed up by immediate corrective action and consultation with all relevant personnel ensures that the PCBU is consistently developing ever-improving systems of safe work principles.

REVIEW NUMBER	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6	<input type="checkbox"/> 7
NAME							
INITIALS							
DATE							

SAFE WORK METHOD STATEMENT REVIEW CHECKLIST			
This Safe Work Method Statement Review Checklist is to be followed and used upon initial development of the SWMS to help ensure that all steps have been adequately taken before work commences. Think of this document as an internal audit review checklist before commencing work, and may form part of a Toolbox Talk (safety meeting) and may be used as an opportunity for education and training.			
ITEMS WHICH MUST BE INCLUDED IN THE SWMS	COMPLETED	TO BE DONE	COMMENTS
The company details have been entered, including the project name and address.	<input type="checkbox"/>	<input type="checkbox"/>	
Names and signatures of all relevant personnel consulted during the development of the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Name, signature, position and date signed of the person approving the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Specific personnel and qualifications, experience is noted in the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Provides a step-by-step process of tasks required to carry out the activity or task.	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate risk assessment of any identified hazards has been completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Foreseeable hazards are identified and documented for each step.	<input type="checkbox"/>	<input type="checkbox"/>	
Any hazards listed in any site risk assessments have been added to the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS initial risk (IR) column as well as residual risk (RR) columns completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Check control measures added to the SWMS are the most effective solutions.	<input type="checkbox"/>	<input type="checkbox"/>	
Responsible person is assigned and listed on the SWMS for the implementation of control measures.	<input type="checkbox"/>	<input type="checkbox"/>	
Permit requirements specified, such as Hot Work, Electrical Work, Work at Heights etc.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS identifies plant and equipment to be used.	<input type="checkbox"/>	<input type="checkbox"/>	
Details of inspection checks required for any equipment listed are noted on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Describes any mandatory qualifications, experience, training, skills required to perform the work.	<input type="checkbox"/>	<input type="checkbox"/>	
Applicable personal protective equipment is selected on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Lists any required permits or licenses.	<input type="checkbox"/>	<input type="checkbox"/>	
Reflects and documents any legislative references and/or Australian Standards.	<input type="checkbox"/>	<input type="checkbox"/>	
Identifies any hazardous substances used with specific control measures in line with any SDS.	<input type="checkbox"/>	<input type="checkbox"/>	
<b>REVIEWED BY</b>		<b>DATE REVIEWED</b>	
<b>SIGNATURE</b>		<b>DATE COMPLETED</b>	